



Solid State Lighting Annex: Product Quality and Performance Tiers

OUTDOOR LIGHTING (STREET LIGHTING)

Energy Efficient End-Use Equipment (4E)
International Energy Agency

NOVEMBER 2016



Performance Tiers Proposed by Governments Participating in the IEA 4E SSL Annex

Government officials from 13 countries participating in the International Energy Agency's Energy Efficient End-use Equipment (IEA 4E) implementing agreement have identified solid state lighting (SSL) technologies as having the potential to cut global lighting electricity consumption by 30%. While SSL technologies promise high performance, the recent experience with compact fluorescent lamps has demonstrated the need to prevent unwarranted performance claims, which can seriously damage consumer confidence and slow down market acceptance of this emerging energy-saving technology.

Twenty technical experts from the SSL Annex's eight member countries: Australia, Denmark, France, Korea, The Netherlands, Sweden, United Kingdom, and United States of America and expert member country China have worked together to develop performance tiers for Light Emitting Diode (LED) based lighting. Several performance tier levels were set to address the various priorities and needs from each country or region. This approach is expected to help participating governments to define globally consistent requirements for programmes to promote market adoption of SSL products, as well as being useful for governments planning to adopt national energy policies and regulations covering SSL technologies.

The SSL Annex has published performance tiers associated with the following LED lamps and luminaires:

1. Non-directional Lamps
2. Directional Lamps
3. Downlight Luminaires
4. Linear LED Lamps Replacing Fluorescent Tubes
5. Outdoor Lighting (Street Lighting)
6. High/Low Bay LED Luminaires (NEW)
7. Planar Luminaires (NEW)

To view these performance tiers, visit our website: <http://ssl.iea-4e.org/product-performance>

The SSL Annex is continuing to monitor the market and the appropriateness of these published tier levels, and fully expects that further revisions will be made in the future as SSL technology advances. The Annex appreciates your interest in this process and welcomes any suggestions or thoughts you may have on these tiers.

Best regards,

Peter Bennich, PhD
Management Committee Chair,
SSL Annex;
Energy Efficiency Department,
Swedish Energy Agency

Nils Borg
Operating Agent
SSL Annex

Professor Georges Zissis
SSL Annex Task Leader
LAPLACE, University of
Toulouse, France

About the IEA 4E Solid State Lighting Annex

The SSL Annex was established in 2010 under the framework of the International Energy Agency's Energy Efficient End-use Equipment (4E) Implementing Agreement to provide advice to its member countries seeking to implement quality assurance programmes for SSL lighting. This international collaboration was established by the governments of Australia, Denmark, France, Japan, The Netherlands, the Republic of Korea, Sweden, United Kingdom and the United States of America. China works as an expert member of the 4E SSL Annex. Further information on the 4E SSL Annex is available from: <http://ssl.iea-4e.org/>

About the IEA Implementing Agreement on Energy Efficient End-Use Equipment (4E)

4E is an International Energy Agency (IEA) Implementing Agreement established in 2008 to support governments to formulate effective policies that increase production and trade in efficient electrical end-use equipment. Globally, electrical equipment is one of the largest and most rapidly expanding areas of energy consumption which poses considerable challenges in terms of economic development, environmental protection and energy security. As the international trade in appliances grows, many of the reputable multilateral organisations have highlighted the role of international cooperation and the exchange of information on energy efficiency as crucial in providing cost-effective solutions to climate change. Twelve countries have joined together to form 4E as a forum to cooperate on a mixture of technical and policy issues focused on increasing the efficiency of electrical equipment. But 4E is more than a forum for sharing information – it initiates projects designed to meet the policy needs of participants. Participants find that pooling of resources is not only an efficient use of available funds, but results in outcomes which are far more comprehensive and authoritative. The main collaborative research and development activities under 4E include:

- The Electric Motor Systems Annex (EMSA)
- The Mapping and Benchmarking Annex
- The Solid State Lighting Annex (SSL)
- The Electronic Devices and Networks Annex (EDNA)

Current members of 4E are: Australia, Austria, Canada, Denmark, France, Japan, Korea, The Netherlands, Switzerland, Sweden, UK and USA. Further information on the 4E Implementing Agreement is available from: www.iea-4e.org

Disclaimer:

The IEA 4E SSL Annex performance tiers are provided for informational purposes only. The purpose of these tiers is to provide governments and market transformation programme managers a basis on which to structure voluntary and mandatory programmes which are harmonised with other programmes around the world, all of which will help to accelerate the market for SSL technology. The final decision to publish the performance tiers is made by the participating SSL Annex governments, following an expert review and public consultation. Neither the IEA 4E SSL Annex and its participating governments, nor the IEA 4E Implementing Agreement make any warranties or guarantees as to the accuracy of data presented herein nor accept any liability for any action taken or decision made based on the contents of this document. Furthermore, it should be noted that this report is issued as advice for governments and does not necessarily reflect the views or policies of the governments who are part of the SSL Annex.

Scope of Coverage and Definitions of Performance Tiers

Scope of coverage for Outdoor Lighting (Street Lighting) Luminaires – luminaires for road, street and tunnel lighting and other public outdoor lighting applications (such as parking lots, pedestrian walkways and bicycle paths).

Tier 1: Minimum Acceptable Performance Level

This tier is intended to represent the minimum acceptable performance level. Products meeting this tier provide quality lighting, use less energy and last longer than the traditional lighting technologies they are intended to replace. The SSL products in this tier have/are:

- Efficacy established at a level at least comparable to high quality compact fluorescent lamps and achievable by 70-80% of non-directional SSL lamps found in the unregulated market;
- Reliability and lamp lifetimes are superior to the lighting products they are intended to replace; and
- Quality of light and the light intensity distribution perceived as roughly equivalent to the conventional technologies they are replacing.

Tier 2: Performance Required by Established Quality Programs

This tier is intended to be similar to the performance requirements for established voluntary programmes that promote quality SSL products. In addition to the objectives set out in Tier 1, the SSL luminaires in this tier have/are:

- Efficacy established at a level exceeding high quality HID luminaires and achievable by the top 20-30% of SSL products found in the unregulated market; and
- Improvement in the quality of light over Tier 1, and other critical performance aspects including lifetime and light distribution pattern.

Tier 3: Current Highest Commercially Available Performance

This tier is set at approximately the highest performing outdoor lighting SSL luminaires available in an unregulated market at the time of publication. Products achieving these performance levels are intended to be equivalent to those participating in premium labelling programmes such as the US Department of Energy's L-Prize, the SEAD global efficiency award programme or the Japanese Top Runner programme.

Table 1. IEA 4E SSL Annex Performance Tiers - Outdoor Lighting (Street Lighting) Luminaires*Note: please see Table 2 for recommended test methods for these parameters*

Parameter	Tier 1	Tier 2	Tier 3																																										
Energy-Efficiency																																													
Minimum downward fixture luminous efficacy (lm/W) ¹	85 lm/W	105 lm/W	120 lm/W																																										
Maximum Standby Power ²	<i>Reserved for future use, but if luminaire has standby power, then it must be reported in watts</i>																																												
Life																																													
Luminous flux maintenance	At 6,000h, ≥ 95.8% of initial (based on L ₇₀ ≥ 50,000h)																																												
Early failure rate (maximum)	Either no failures at 3,000 hours or ≤10% failures at 6000 hours with a sample size of 10 units																																												
Minimum rated luminaire lifetime (F ₅₀)	At 50,000h < 50% have failed																																												
Colour																																													
Colour rendering index (CRI) ³	Ra ≥ 70																																												
Colour maintenance (Δu',v' at 6,000h)	≤ 0.007																																												
Chromaticity tolerance	<table border="1"> <thead> <tr> <th>Nominal CCT (K)</th> <th>Target CCT and Tolerance (K)</th> <th>Target Duv</th> <th>Duv Tolerance Range</th> </tr> </thead> <tbody> <tr> <td>2200</td> <td>2238 ± 102</td> <td>0.0000</td> <td rowspan="2">T_x: CCT of the source For T_x < 2870K 0.000 ± 0.0060</td> </tr> <tr> <td>2500</td> <td>2460 ± 120</td> <td>0.0000</td> </tr> <tr> <td>2700</td> <td>2725 ± 145</td> <td>0.0000</td> <td rowspan="2">For T_x ≥ 2870K D_w(T_x) ± 0.0060 where D_w(T_x) = 57700 × (1/T_x)² - 44.6 × (1/T_x) + 0.00854</td> </tr> <tr> <td>3000</td> <td>3045 ± 175</td> <td>0.0001</td> </tr> <tr> <td>3500</td> <td>3465 ± 245</td> <td>0.0005</td> <td></td> </tr> <tr> <td>4000</td> <td>3985 ± 275</td> <td>0.0010</td> <td></td> </tr> <tr> <td>4500</td> <td>4503 ± 243</td> <td>0.0015</td> <td></td> </tr> <tr> <td>5000</td> <td>5029 ± 283</td> <td>0.0020</td> <td></td> </tr> <tr> <td>5700</td> <td>5667 ± 355</td> <td>0.0025</td> <td></td> </tr> <tr> <td>6500</td> <td>6532 ± 510</td> <td>0.0031</td> <td></td> </tr> </tbody> </table>			Nominal CCT (K)	Target CCT and Tolerance (K)	Target Duv	Duv Tolerance Range	2200	2238 ± 102	0.0000	T _x : CCT of the source For T _x < 2870K 0.000 ± 0.0060	2500	2460 ± 120	0.0000	2700	2725 ± 145	0.0000	For T _x ≥ 2870K D _w (T _x) ± 0.0060 where D _w (T _x) = 57700 × (1/T _x) ² - 44.6 × (1/T _x) + 0.00854	3000	3045 ± 175	0.0001	3500	3465 ± 245	0.0005		4000	3985 ± 275	0.0010		4500	4503 ± 243	0.0015		5000	5029 ± 283	0.0020		5700	5667 ± 355	0.0025		6500	6532 ± 510	0.0031	
	Nominal CCT (K)	Target CCT and Tolerance (K)	Target Duv	Duv Tolerance Range																																									
	2200	2238 ± 102	0.0000	T _x : CCT of the source For T _x < 2870K 0.000 ± 0.0060																																									
	2500	2460 ± 120	0.0000																																										
	2700	2725 ± 145	0.0000	For T _x ≥ 2870K D _w (T _x) ± 0.0060 where D _w (T _x) = 57700 × (1/T _x) ² - 44.6 × (1/T _x) + 0.00854																																									
	3000	3045 ± 175	0.0001																																										
	3500	3465 ± 245	0.0005																																										
	4000	3985 ± 275	0.0010																																										
	4500	4503 ± 243	0.0015																																										
	5000	5029 ± 283	0.0020																																										
5700	5667 ± 355	0.0025																																											
6500	6532 ± 510	0.0031																																											
Parameter Common to some or all Tiers																																													
Operation																																													
Ambient Operating temperature (range °C)	Temperature range from -30°C to 50°C without significant change of photometric and colourmetric performance, unless regional requirements are higher or lower																																												
Harmonic distortion	For products >25W within IEC 61000-3-2, Table 2, Limits for Class C equipment. ⁴	<table border="1"> <thead> <tr> <th>Harmonic Order</th> <th>Maximum permissible harmonic current expressed as a percentage of the input current at the fundamental frequency (%)</th> </tr> </thead> <tbody> <tr> <td>n</td> <td>(%)</td> </tr> <tr> <td>2</td> <td>2</td> </tr> <tr> <td>3</td> <td>30 - CPF *</td> </tr> <tr> <td>5</td> <td>10</td> </tr> <tr> <td>7</td> <td>7</td> </tr> <tr> <td>9</td> <td>5</td> </tr> <tr> <td>11 ≤ n ≤ 39 (odd harmonics only)</td> <td>3</td> </tr> </tbody> </table>		Harmonic Order	Maximum permissible harmonic current expressed as a percentage of the input current at the fundamental frequency (%)	n	(%)	2	2	3	30 - CPF *	5	10	7	7	9	5	11 ≤ n ≤ 39 (odd harmonics only)	3																										
		Harmonic Order	Maximum permissible harmonic current expressed as a percentage of the input current at the fundamental frequency (%)																																										
		n	(%)																																										
		2	2																																										
		3	30 - CPF *																																										
		5	10																																										
7	7																																												
9	5																																												
11 ≤ n ≤ 39 (odd harmonics only)	3																																												
* CPF is the circuit power factor																																													
Power factor (PF)	All luminaires, PF > 0.90																																												
Glare	Must meet regional requirements for glare																																												

¹ The efficacy calculation shall be based on initial luminous flux measurements according to CIE S 025/E (or IES LM-79).² Maximum Standby Power applies to smart luminaires with wireless illumination control activated in the default (factory setting) mode. These smart luminaires remain 'on' while the lamps emit no light. For the default mode, all other features that provide lighting control (e.g., movement sensor) or functions are to be deactivated. The IEA/G20 will continue to research different types of smart lighting and provide advice to governments.³ Please see Table 2 for a note about Colour Rendering Index⁴ For products 5W < P ≤ 25W: requirement to be developed pending amendment to 61000-3-2 – and update to these specifications will be made following release.

Parameter	Tier 1	Tier 2	Tier 3
Health			
Photobiological risk group (blue light and UV hazard) ⁵	For the blue light hazard: RG0 or RG1. If an LED uses a UV-based LED chip, then it must meet UV RG0 and RG1. Luminaires other than RG0 or RG1 are allowed only if the threshold distance defined by IEC TR 62778 is specified and the product is labelled with the eye safety marking according to IEC TR 62471-2. The risk group (RG) is assessed at 200 mm from the lamp using the general methodology of IEC 62471 and the particular prescriptions of IEC TR 62778.		
Safety	Must meet regional and/or national requirements for material safety, and mechanical and electrical appliance safety laws, including electromagnetic compatibility (EMC) requirements, and requirements for labelling / marking.		
Environment			
Up-light (emissions above the horizontal)	Luminous intensity distribution must be provided by manufacturer and >95% of total light output will be emitted below the horizontal (90 degrees) (Note: Local regulations may have more stringent requirements for upward light)		
RoHS compliant	Yes, unless other regional or national requirements apply.		
Recyclable content (%)	The manufacturer shall provide data concerning the recyclable content in percentage by weight, together with the associated recycling codes or symbols (metal, plastics, glass, etc.) of the recyclable materials. This declaration should be made in the form of a type III Environmental Product Declaration (EPD).		

⁵ The blue light hazard assessment is based on IEC 62471 and IEC TR 62778:2015.

Table 2. Performance Criteria included in the IEA 4E SSL Annex Product Tiers Documents

Criterion	What is it?	Why is it included?	Test Method
Minimum downward fixture luminous efficacy (lm/watt)	The ratio of the total light output of the luminaire compared to power consumed (lm/watt). The higher the efficacy value, the more energy-efficient the luminaire.	This criterion is of highest importance for the consumer and society to save energy and money.	CIE S 025/E (or IES LM-79)
Maximum Standby Power	Maximum Standby Power applies to the default (factory setting) mode of smart luminaires and other modes that provide a lighting control function, and which remain 'on' when emitting no light. The IEA/G20 will continue to research this topic plus other types of smart lighting and provide advice to governments.	As wireless control of lighting expands in the market, this criterion is important for the consumer and society so as to ensure minimal additional power consumption associated with new lighting control features.	IEC 62301
Luminous flux maintenance	The percentage of a lighting product's measured light output after a period of time compared to that light product's initial total light output, based on either using IESNA LM-80/TM-21 or IESNA LM-84/TM-28.	Lumen Maintenance helps the consumer determine how long it will take a lighting product to degrade to the point that it is no longer useable. High lumen maintenance over time helps to justify the higher initial cost of SSL lighting products.	IES LM-80/TM-21 or IES LM-84/TM-28. It is expected from 2017 onwards only LM-84 / TM-28 may be accepted
Early failure rate (maximum)	The percentage of luminaires in a sample that fail at a specified point in time (6000 hours).	Early failure rates should be as low as possible in order to minimise the risk that new customers to LED lighting will have a bad experience and the luminaire itself will fail to achieve its full potential of energy savings. It is also an alternative indicator of longevity in the absence of a practical lifetime test.	IES LM-80
Minimum rated luminaire lifetime (F_{50})	Lifetime is typically defined as the amount of time that it takes for 50% of a statistically significant sample to fail.	It is unrealistic to measure very long lifetimes for SSL products. Having a credible F_{50} estimation is very important, as LED lighting products must have longer lifetimes to justify the high initial cost of LED lighting. If SSL products are able to meet their lifetime claims, they can cut long-term energy consumption and save the consumer money.	

Criterion	What is it?	Why is it included?	Test Method
Colour rendering index (CRI)	Colour rendering is a measure of how similar object colours appear under one light source as compared to the object colours under a reference light source (usually an incandescent light or daylight). Colour rendering is very important for consumer satisfaction with a lighting product. Often, a CRI of 80 is required for office work, and recommended for use in residential applications. A CRI of 90 is recommended for tasks that require high colour discrimination.	The IEA SSL Annex is aware of current investigations and discussions of shortcomings of the CRI metric that limit its ability to fully represent how humans perceive colour for SSL technology; and the potential need for both a colour fidelity metric and a colour preference metric. The IEA SSL annex is monitoring the work of the IES (in particular the release of TM-30) as well as the ongoing work in CIE, and will take this work into account in future updates of the SSL Annex performance specifications.	CIE 13.3-1995
Colour maintenance ($\Delta u', v'$ at 6,000h)	This criterion specifies the allowable shift of the light colour of a SSL package as it ages, based on either using IESNA LM-80/TM-21 or IESNA LM-84/TM-28.	This criterion ensures that as a light product ages, the perceived colour of light does not shift from warm- white to cool-white or develop a green or pink tint. If an SSL lamp or luminaire in a large installation is replaced by a new light product of the same model, this criterion ensures that the new product's colour will be similar to those installed around it.	IES LM-80/TM-21 or IES LM-84/TM-28. It is expected from 2017 onwards only LM-84 / TM-28 may be accepted
Chromaticity tolerance	This criterion specifies the allowable deviation in light's colour. Technically, it is the distance of a light's chromaticity from the Planckian (black body) locus and target CCT.	This criterion is of high importance to ensure that the light from an LED product does not have an unacceptable pink or green tint. This criterion attempts to ensure that all lamps and luminaires of the same claimed colour temperature appear to be the same colour when installed.	ANSI C78.377-2015
Ambient Operating temperature (range °C)	The operating temperature represents the range of temperatures that a luminaire manufacturer has determined it is safe to use the luminaire. A luminaire should not be used outside these temperatures.	The operating temperature range for the luminaire is shown on the rating label and represents an important safety consideration for an installation.	
Harmonic distortion	The total harmonic distortion of the current is the RMS-sum of all the harmonic currents divided by the current at the fundamental frequency (50 Hz or 60 Hz). $THD = \frac{\sqrt{\sum_{n=2}^{\infty} I_n^2}}{I_1}$	Harmonic distortion measures how the lighting product might affect the quality and safety of the electrical utility's grid. The total harmonic distortion is important to maintain the quality and safety of the electrical grid. High frequency harmonic currents emitted by electrical devices such as lamps may trigger circuit breakers, may cause overheating in cables (lost energy) and electrical distribution devices and may cause a loss of reliability of switch pulse information.	IEC 61000-4-7

Criterion	What is it?	Why is it included?	Test Method
Power factor	Power factor is the ratio of the active power flowing to the load over the apparent power of the circuit (see IEC IECV ref 131-11-46). We recognise that in many cases the IEC requirements on total harmonic distortion (THD) will lead to a higher power factor (PF) than the minimum level required in the performance tiers, but we follow IEC standards and believe the most critical electrotechnical requirements are set through the THD requirements.	For the Electrical power supplier, power factor is of high importance. For street lighting and commercial or industrial lighting; customers may be subject to a penalty charge if power factor is below 0.9. The importance of high power factor may vary depending on the nature of the power distribution network.	IEC 61000-3-2
Glare	This performance criterion relates the point where the amount of light becomes physically painful to experience or makes it difficult to see. Products should conform to safety requirements for glare.	High importance for safety, health, and comfort.	
Photo-biological risk group (blue light and UV hazard)	Photobiological risk groups are defined in IEC 62471, with additional information given in IEC TR 62471-2 and IEC TR 62778. There is a potential risk of retinal damage when the blue light radiance is too high. The criterion sets a limit to the blue light dose that the retina can receive.	This criterion is very important for consumer safety. Blue light can cause irreparable damage to eyesight at high doses. Products need to be evaluated to determine their appropriate photobiological risk group.	IEC 62471-2/ CIE S 009 and IEC TR 62778
Safety	This criterion specifies that a product meets mechanical and electrical safety requirements and marking requirements.	All products must meet all safety regulations in an economy.	IEC 60598 series
Up-light (emissions above the horizontal)	Percentage of the total flux emitted from a luminaire above a horizontal plane passing through the centroid of a luminaire.	Uplight contributes to sky glow, diminishing night sky viewing, and for many types of outdoor luminaires, needlessly wastes light and energy. This criterion may be subject to local regulations that have more stringent requirements on uplight.	CIE S 025/E
RoHS compliant	The EU's Regulation of Hazardous Substances (RoHS), Delegated Directive (EU) 2015/863 of 31 March 2015, prevents the use of certain hazardous materials in new electrical and electronic equipment placed on the European market.	This criterion requires products meet requirements that limit the use of certain hazardous materials when sold in the EU. Non-EU countries may use other, similar requirements.	
Recyclable content (%)	This criterion defines how much of the SSL product must be recyclable: <ul style="list-style-type: none"> Recyclable content, expressed in percentage by weight (wt%) The nature of the recyclable materials, stated by recycling codes or recycling symbols 	This criterion is important to manage electronic equipment waste and reduce the environmental burden of these products. Ideally, products would be designed to be easily recycled when they fail.	ISO 14021; ISO 14025:2006